



Notified body No. 0370



CERTIFICATE

Nr.

0370-CPD-1365

EC-CERTIFICATE OF CONFORMITY

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product:

SMOKE AND HEAT CONTROL SYSTEMS. PART 3. SPECIFICATIONS FOR MECHANICAL SMOKE AND HEAT EXTRACTOR VENTS: CENTRIFUGAL JET FAN ECRJ 60

| | |
|-----------------------|-------|
| EN 12103-3 TEST CLASS | F300 |
| TEST TEMPERATURE | 300°C |
| TEST TIME (HOURS) | 2 |

Placed on the market by:

**EMAK SOĞUTMA ISITMA VE ENDÜSTRİ MAKİNALARI İMALAT VE MONTAJ SAN. LTD. STİ.
ILK BELEDİYE CAD. No: 2 TÜNEL
34420 BEYOĞLU – İSTANBUL (TÜRKİYE)**

And produced in the factory:

**EMAK SOĞUTMA ISITMA VE ENDÜSTRİ MAKİNALARI İMALAT VE MONTAJ SAN. LTD. STİ.
Karayolları Mahallesi, Kadir Akdoğan Caddesi, No:28
Küçükköy - İstanbul (Türkiye)**

Is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body – LGAI TECHNOLOGICAL CENTER, S.A. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in the Annex ZA of the standard were applied and that the product fulfils all the prescribed requirements.

EN 12101-3:2002, EN 12101-3:2002/AC:2005

This certificate was first issued on 20th July 2012 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Bellaterra, 20th July 2012

Jordi Brufau Redondo
General Manager

Xavier Ruiz Peña
Product Conformity B.U., Manager